

Keep dry - handle carefully

**MICROBIOLOGY REPORT FORM - WATER SAMPLES**

Page of 2

Date Commenced Laboratory: 19/02/08

Time Commenced Laboratory: 9.15

FEB 19 8:06

Submitted by: Charles Wilson - iPools Australia P/L  
 Postal Address: 7 Pinari Court, Mountain Creek QLD 4557  
 Phone: (07)54446754 Fax: (07)54446578

**Public Health Microbiology**  
**Queensland Health Scientific Services**  
 39 Kessels Road  
 COOPERS PLAINS Q. 4108  
 P.O. Box 594  
 ARCHERFIELD Q. 4108  
 Ph: 3274 9075 Fax: 3274 9022



Queensland Health  
**Scientific Services**  
 Queensland Government

Taken by: Charles Wilson Order No: (if required) \_\_\_\_\_

Batch Reference (Lab) W 542/08  
 Billing Reference (MARS): NW \_\_\_\_\_

Office Use	Client Sample Reference	Date and Time Taken	Sample point - Source of water: Full details	Treatment Details/Field Measurements: pH, Chlorine, Turbidity	Human Consumption	Rain Water Tank	Indicate Other Sample Types Swimming Pool, Spa Pool, Recreational, Sewage Effluent, Other	LABORATORY RESULTS (laboratory use only)							
								Heterotrophic Colony Count: CFU per mL at 36°C	Coliforms: MPN per 100 mL	E. coli: MPN per 100 mL	Pseudomonas aeruginosa: CFU per 100 mL	Thermotolerant (Faecal) Coliforms: CFU per 100 mL	Enterococci: CFU/100mL		
08	A 1981	RAW 18/2 9.15	Backwash from Noosa Aquatic Centre - pre and post treatment					✓	> 2000	✓	ND	✓	32	✓	EST 2
08	B 10781	9.15	Treated						43		ND		ND		ND

ADDITIONAL INFORMATION (including reasons for sampling)  
 Please test for Heterotrophic Colony Count, E. coli, Ps. aeruginosa & Enterococci.  
 Signed: \_\_\_\_\_

Test Method(s): **Test Method SHW 1.2, 5 & 17, 6**  
 Comment: These results relate to the samples as received. The responsibility for sampling rests with the client.  
 Signed: \_\_\_\_\_ (NATA Signatory) Date Completed in Laboratory: 26/2/08

**NATA**  
 NATA Accredited Laboratory Number 41  
 NATA endorsed test report. This document  
 May not be reproduced except in full.  
 National Association of Testing Authorities  
 Australia

ADDITIONAL INFORMATION/COMMENTS  
B. GRAY  
**N.A.T.A. SIGNATORY**

CFU = Colony Forming Units  
 MPN = Most Probable Number  
 EST = Estimated Count  
 ND = Not Detected  
 + = Detected. No count due to confluent growth

28/02 2008 THU 16:52 FAX 61 7 3274 9175 PUBLIC HEALTH MICRO