

Keep dry - handle carefully

MICROBIOLOGY REPORT FORM - WATER SAMPLES

Page of

Date Commenced 28/2/08 Time Commenced 9.20  
 Laboratory: Laboratory:

08:16 28FEB'08 RCUD

Submitted by: Charles Wilson - iPools Australia P/L  
 Postal Address: 7 Pinari Court, Mountain Creek QLD 4557  
 Phone: (07)54446754 Fax: (07)54446578

Public Health Microbiology  
 Queensland Health Scientific Services  
 39 Kessels Road  
 COOPERS PLAINS Q. 4108  
 P.O. Box 594  
 ARCHERFIELD Q. 4108  
 Ph: 3274 9075 Fax: 3274 9022



Queensland Health  
**Scientific Services**  
 Queensland Government

Taken by: Charles Wilson Order No: (if required)

Batch Reference (Lab) W 720/08  
 Billing Reference (MARS): NW

Office Use Queensland Health Scientific Services Sample Reference	Client Sample Reference	Date and Time Taken	Sample point - Source of water: Full details	Treatment Details/Field Measurements: pH, Chlorine, Turbidity	Human Consumption	Rain Water Tank	Indicate Other Sample Types Swimming Pool, Spa Pool, Recreational, Sewage Effluent, Other	LABORATORY RESULTS (laboratory use only)							
								Heterotrophic Colony Count: CFU per ml, at 36°C	Coliforms: MPN per 100 ml.	E. coli: MPN per 100 ml.	Pseudomonas aeruginosa: CFU per 100 ml.	Thermotolerant (Fuscal) Coliforms: CFU per 100 ml.	Enterococci: CFU/100mL		
08	2595		Backwash from Noosa Aquatic Centre- Raw Water					✓	710,000	✓	3	✓	EST 700.	✓	EST 5
08	2596		Backwash from Noosa Aquatic Centre - Treated Water					✓	43	✓	ND	✓	ND	✓	ND

ADDITIONAL INFORMATION (Including reasons for sampling)  
 Please test for Heterotrophic Colony Count, E. coli, Ps. aeruginosa & Enterococci.  
 Signed: *[Signature]*

Test Method(s): Test Method SHW 1.2, 5 & 17  
 Comment: These results relate to the samples as received. The responsibility for sampling rests with the client.  
 Signed: *[Signature]* (NATA Signatory) Date Completed in Laboratory: 5/3/08

NATA Accredited Laboratory Number 41.  
 NATA endorsed test report. This document may not be reproduced except in full.  
 National Association of Testing Authorities, Australia

ADDITIONAL INFORMATION/COMMENTS  
 B. GRAY  
 N.A.T.A. SIGNATORY

CFU - Colony Forming Units  
 MPN - Most Probable Number  
 EST - Estimated Count  
 ND - Not Detected  
 + = Detected. No count due to confluent growth

05/03 2008 WED 18:03 FAX 61 7 3274 9175 PUBLIC HEALTH MICRO